

PROFORMA REGARDING SAFE DRINKING WATER AND SANITARY CONDITION CERTIFICATE

No. 329/R (2021-2022)

Date: 15-12-2021

It is certified that inspection team headed by Bhupendra Kumar

(Name of Officers with designation) from A.E. Incharge (Civil) U.P. JV. Azamgarh (Name of

Department/Office) inspected the **ABHINAV VIDYALAYA TERAHI, AZAMGARH, 276141** on

15-12-2021 and found that the **ABHINAV VIDYALAYA TERAHI, AZAMGARH, 276141** has safe drinking water facilities for the students and members of staff of the institution and is maintaining the hygienic sanitation condition in the school building & the campus as per the norms prescribed by the Central/state/U.T. Govt.

The above is valid for a period of 6th Months

Signature with Seal: \_\_\_\_\_

Name: सहोयक अभियन्ता

Designation: द्वितीय निर्माण खण्ड  
उ०प्र० जल निगम  
आजमगढ़।

To,

The Principal,

ABHINAV VIDYALAYA TERAHI,

AZAMGARH, 276141

# जनपदीय जल विश्लेषण प्रयोगशाला, आजमगढ़

अधिशाली अभियन्ता, द्वितीय निर्माण खण्ड

उ०प्र० जल निगम, आजमगढ़ (उ०प्र०)

बिल सं० 144 (2021-2022)

दिनांक 15-12-2021

सेवा में .....

Principal .....

Abhinav Vidyalaya Terahi Azamgarh

विवरण

सेम्पलों की संख्या

दर प्रति सेम्पल

कुल धनराशि

Drinking water sample

1

1980.00

1980.00

Test Report

(One Thousand Nine Hundred Eighty Rupee)

→ योग

1980.00

1980.00

नियन्त्रक प्रयोगशाला / अधिशाली अभियन्ता

द्वितीय निर्माण खण्ड

उ०प्र० जल निगम, आजमगढ़ (उ०प्र०)



# District Water Analysis Laboratory IInd G.D. U. P. Jal Nigam, Azamgarh

Drinking Water Sample Test Report

Report No. ... 329 (2021-22) ...  
 Distt. 57 Azamgarh Date: ... 15/12/2021 ...  
 Revenue Village Tarshi Azamgarh Block Mahraiganj Gram Panchayat Tarshi  
 H.P. Code \_\_\_\_\_ Habitation School Location Abhinav School  
 Name & Designation of sample collector principal (School) ...  
 Date & Time of Sampling 15/12/2021 ...  
 Date of Analysis ... 15/12/2021 ...

(A) CHEMICAL ANALYSIS	Unit	Test	Indian Standards	
	Mg/Lit.	Result	Acceptable	Cause of Rejection
1- Total dissolved solids	"	334	500	1500
2- Chloride (as Cl)	"	66	200	1000
3- Total Hardness (as CaCo3)	"	210	200	600
4- Alkalinity	"	78	200	600
(a) Phenolphtheline	"			
(b) Methyl Orange	"			
5- Sulphate	"	84	200	400
6- Nitrite (No2) as Nitrite (No2)	"	Nil		
7- Nitrate (No3) as Nitrate (No3)	"	28	45	45
8- Fluorides as F	"	0.8	1.0	1.5
9- Residual Chlorine	"	—	0.2	0.5
10- Iron as Fe	Mg/Lit.	0.2	0.1	1.0

**(B) PHYSICAL EXAMINATION**

	Unobjectionable	Objectionable
a- Taste	✓ Unobjectionable	Objectionable
b- Colour	5	16 25
c- Odour	✓ Unobjectionable	Objectionable
d- Turbidity	NTU 1	6 10
e- pH	7.0 to 8.5	7.0 6.5 to 9.2

पेय जल गुणवत्ता

सन्तोषजनक/असन्तोषजनक

*(Signature)*  
 प्रभारी  
 जलपरीक्षण विभाग  
 प्रयोगशाला, आज़मगढ़

*(Signature)*  
 Lab. Asstt.